

**City of Norwalk
CSO 7-Day Supplemental Notification Form**

| CSO Outlet # | CSO Outlet Name | Receiving Stream | Date/Time CSO Started (Estimate) | Date/Time CSO Ended (Estimate) | Length of Overflow (Hours) (Estimate) | Total Volume of Discharge (Million Gallons)(Estimate) |
|--------------|-------------------|---------------------------------|----------------------------------|--------------------------------|---------------------------------------|---|
| 003 | Cline St CSO | Rattlesnake Creek (East Branch) | 3/3/23, ~2:00 pm | 3/4/23, ~1:15 pm | 23.3 | 0.160 |
| Unnumbered | Big Lots CSO | Rattlesnake Creek (East Branch) | 3/3/23, ~2:00 pm | 3/4/23, ~1:15 pm | 23.3 | 0.160 |
| 004 | Washington St CSO | Rattlesnake Creek (West Branch) | 3/3/23, ~3:15 pm | 3/4/23, ~4:45 pm | 25.5 | 3.00 |

Rain Data:

| Date/Time Rain Event Started | Date/Time Rain Event Ended | Duration of Rain Event (Hours) | Amount of Rain Received (Inches) |
|------------------------------|----------------------------|--------------------------------|----------------------------------|
| 3/3/23, ~11:00 am | 3/3/23, ~9:30 pm | 10.50 | 1.20 |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| Total | | 10.50 | 1.20 |

| |
|--|
| Date Posted to www.norwalkoh.com/wastewater-treatment |
| 3/3/23 |