

Client Sample Results

Client: City of Norwalk
 Project/Site: Norwalk WTP - Drinking Water MIB / Geosmin

Job ID: 810-84793-1

Client Sample ID: RW - LT2001

Lab Sample ID: 810-84793-1

Date Collected: 11/13/23 07:06

Matrix: Drinking Water

Date Received: 11/14/23 09:00

PWSID Number: OH3901111

Method: Lab SOP V210 - Taste and Odor Compounds (GC/MS/SIS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
2,4,6-Trichloroanisole (TCA)	<2.0		2.0		ng/L			11/16/23 12:02	1
2-Methylisoborneol (MIB)	97		2.0		ng/L			11/16/23 12:02	1
Isopropyl methoxy pyrazine (IPMP)	<2.0		2.0		ng/L			11/16/23 12:02	1
Isobutyl methoxy pyrazine (IBMP)	<2.0		2.0		ng/L			11/16/23 12:02	1
Geosmin	<2.0		2.0		ng/L			11/16/23 12:02	1

5

Client Sample ID: Tap - EP001

Lab Sample ID: 810-84793-2

Date Collected: 11/13/23 07:09

Matrix: Drinking Water

Date Received: 11/14/23 09:00

PWSID Number: OH3901111

Method: Lab SOP V210 - Taste and Odor Compounds (GC/MS/SIS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
2,4,6-Trichloroanisole (TCA)	<2.0		2.0		ng/L			11/16/23 12:29	1
2-Methylisoborneol (MIB)	78		2.0		ng/L			11/16/23 12:29	1
Isopropyl methoxy pyrazine (IPMP)	<2.0		2.0		ng/L			11/16/23 12:29	1
Isobutyl methoxy pyrazine (IBMP)	<2.0		2.0		ng/L			11/16/23 12:29	1
Geosmin	<2.0		2.0		ng/L			11/16/23 12:29	1

Client Sample Results

Client: City of Norwalk
 Project/Site: Drinking Water MIB / Geosmin

Job ID: 810-86651-1

Client Sample ID: Raw - LT2001

Lab Sample ID: 810-86651-1

Date Collected: 12/04/23 07:32

Matrix: Drinking Water

Date Received: 12/05/23 09:15

PWSID Number: OH3901111

Method: Lab SOP V210 - Taste and Odor Compounds (GC/MS/SIS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
2,4,6-Trichloroanisole (TCA)	<2.0		2.0		ng/L			12/06/23 13:20	1
2-Methylisoborneol (MIB)	110		2.0		ng/L			12/06/23 13:20	1
Isopropyl methoxy pyrazine (IPMP)	<2.0		2.0		ng/L			12/06/23 13:20	1
Isobutyl methoxy pyrazine (IBMP)	<2.0		2.0		ng/L			12/06/23 13:20	1
Geosmin	<2.0		2.0		ng/L			12/06/23 13:20	1

5

Client Sample ID: Tap - EP001

Lab Sample ID: 810-86651-2

Date Collected: 12/04/23 07:35

Matrix: Drinking Water

Date Received: 12/05/23 09:15

PWSID Number: OH3901111

Method: Lab SOP V210 - Taste and Odor Compounds (GC/MS/SIS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
2,4,6-Trichloroanisole (TCA)	<2.0		2.0		ng/L			12/06/23 14:15	1
2-Methylisoborneol (MIB)	71		2.0		ng/L			12/06/23 14:15	1
Isopropyl methoxy pyrazine (IPMP)	<2.0		2.0		ng/L			12/06/23 14:15	1
Isobutyl methoxy pyrazine (IBMP)	<2.0		2.0		ng/L			12/06/23 14:15	1
Geosmin	<2.0		2.0		ng/L			12/06/23 14:15	1

Client Sample ID: Basin

Lab Sample ID: 810-86651-3

Date Collected: 12/04/23 07:45

Matrix: Drinking Water

Date Received: 12/05/23 09:15

PWSID Number: OH3901111

Method: Lab SOP V210 - Taste and Odor Compounds (GC/MS/SIS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
2,4,6-Trichloroanisole (TCA)	<2.0		2.0		ng/L			12/06/23 14:43	1
2-Methylisoborneol (MIB)	87		2.0		ng/L			12/06/23 14:43	1
Isopropyl methoxy pyrazine (IPMP)	<2.0		2.0		ng/L			12/06/23 14:43	1
Isobutyl methoxy pyrazine (IBMP)	<2.0		2.0		ng/L			12/06/23 14:43	1
Geosmin	<2.0		2.0		ng/L			12/06/23 14:43	1